

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATENo. 115.....Dated: 08.05.2023.....

It is certified that an inspection team headed by Sanjay Dubey.....
Chemist & Incharge (Name of Officers with designation) from
District Water Test Lab Vidisha
Govt. of MP PHED (Name of Department/ Office) inspected the
Trinity Convent Sr. Sec. School..... (Name & Address of the
school) on 8.05.2023 (date of inspection), checked the water test report submitted by the
school and found that the school has potable drinking water for students and staff of the
institution and is having provision for running water in the toilets and maintaining hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of one year.....Signature with Seal: Anbeey.....Name: Sanjay Dubey.....Designation: Chemist & Incharge
District Lab PHED, Vidisha.....Assistant Engineer of the Govt. Public Health Department
(PHED) / Authorised officer of the Local BodyName & Address of the Office / Department: PHED.....

To

Trinity Convent Sr. Sec.
School, Vidisha

(Name & Address of the Institution)

Omama T.O.

Manager
Trinity Convent
Sr. Sec. School
Vidisha (M.P.) 464001

Omama
Principal
Trinity Convent
Sr. Sec. School
Vidisha (M.P.)

DISTRICT WATER TESTING LABORATORY PHED Division VIDISHA

Near Ramlila Maidan Drainage colony Mandi road Vidisha -464001

Test Report

Desp. No. 115



Date 08.05.2023

Report No 115 Date 08.05.2023

A Name and address

Trinity Convent Senior Sec. School Vidisha


2. Particulars of a sample place of collection & Details


8 Reference No. Nil
 3 Date and Time of sample receive 08.05.23
 4 Date of analysis start 08.05.23
 3 Date of analysis end 08.05.23
 4 Unique ID 127
 5 Condition of the sample Ok/Not Ok OK

1	Vidisha - TW, TrinitynConvent Senior Sec. School Vidisha

S.No.	Name of parameter	Name of test methods used	BIS 10500:2012 Reaffirmed in Sep. 2018		Unit	Unique ID				
			desireble limits	Permissible limits		127				
1	Tempraturre	Celsius			Degree C	32C				
2	Turbidity	part 10	1	5	NTU	0.90				
3	Colour	part 04	5	15	Hazon Scale	Nil				
	Taste	Part 7, 8	Agreeable	Not Agreeabl	None	Agreeable				
4	Odour	part 05	Agreeable	Not Agreeabl	None	Agreeable				
5	pH	Part 11	6.5 -8.5	No relax.	pH Scale	6.00				
6	Conductivity	Part 16			Micromho/cm	130				
7	Total solids	Part 16	500	2000	Mg/L	77				
8	Total Alkalinity	Part 23	200	600	Mg/L	124				
9	Total Hardness as Caco3	Part 21	200	600	Mg/L	136				
10	Ca as Ca++	Part 40	75	200	Mg/L	16				
11	Mg as Mg++	Part 46	30	100	Mg/L	15				
12	Chloride	Part 32	250	1000	Mg/L	95				
13	Nitrate as No3	Part 34	45	45	Mg/L	2.10				
14	Iron	Part 53	0.3	0.3	Mg/L	0.19				
15	Fluoride	Part 60	1	1.5	Mg/L	0.38				
16	Sulfate	Part 24	200	400	Mg/L	3.00				
17	Magnese	Part 59	0.1	0.3	Mg/L	Nil				
18	Arsenic	Part 37	0.01	0.05	Mg/L	Nil				
19	Feacal coliform	Part 10	0/100	0/100	per 100 ml	0.00				
20	Total coliform	Part 10	0/100	0/100	Per 100 ml	0.00				

- Note: 1 Sample has been provided by the customer and Sample tested as received.
 2 The result applied to sample as received.
 3 Report shall not be reproduce except in full without approval of the laboratory.
 4. Sample will be retained for 15 days.


 Signature of analyst
 District water testing laboratory Vidisha (M.P.)


 Sanjay Dubey
 Authorised Signatory & Quality manager
 District Water testing laboratory Vidisha (M.P.)